

Washer, Electrical Equipment Bond



INSTALLATION INSTRUCTIONS

For SnapNrack Only

Please read carefully before installing.



WEEB-PMC



WEEB Bonding Jumper-6.7



WEEBL-6.7 assembly

Products are tested to UL 467 UL standard for safety grounding and bonding equipment



Document Number 104-0404-000034-008

Wiley Electronics LLC. 2006-2010© - All Rights Reserved

WEEB COMPATIBILITY

The WEEB family of products can be used to bond anodized aluminum, galvanized steel, steel and other electrically conductive metal structures.

Standard Top Down Clamps

The WEEBs used for bonding the PV modules to the mounting rails are compatible with various cross-sections of module frames. The following are examples of module frames that are compatible. Notice that the WEEB teeth are positioned completely under the edge of the module frame.



The following is an example of a module frame that is incompatible with the WEEB. The WEEB teeth are positioned only partially under the edge of the module due to the lip on the top edge of the module.



WEEB COMPATIBILITY

Module frames like those shown here may have a ridge or lip on the bottom edge of the frame that would prevent the WEEB teeth from fully embedding.



Important Note:

Inspect each module frame used with a WEEB to ensure that the bottom mounting face of the frame is flat, and that there are no hinderances to embedding WEEB teeth. Do not use a module with a frame that prevents the WEEB teeth from embedding fully.

WEEB-PMC on SnapNrack System

The WEEB-PMC is compatible with the SnapNrack system. However, due to the width of the SnapNrack mid clamp, only module frames with reinforcing box structures can be used for grounding with the WEEB. Below are specifications for such module frames.



SYSTEM OVERVIEW



Use one WEEBL-6.7 assembly per rail to connect system to equipment ground conductor.

Important notes

- 1. Use general purpose anti-seize compound on fastener threads when installing WEEBs.
- 2. WEEBs are intended for SINGLE USE ONLY. Functionality will not be guaranteed if reused.

WEEB-PMC ASSEMBLY



1

Pre-assemble WEEB-PMC to mid-clamp assembly as shown. Pre-assembling WEEB-PMC to mid-clamp assembly will contain the small individual parts, reducing the possibility of losing parts during installation.





(4) Important note:

WEEBs are for SINGLE USE ONLY! Do not torque fasteners down if position of solar modules is not finalized. Only slightly tighten fasteners to keep modules in place.



WEEB-PMC LAYOUT

EVEN NUMBER OF MODULES IN ROW



X DENOTES PLACES TO INSTALL WEEB-PMC

C X R = 4 X 1WEEB-PMC NEEDED = C X R = 4 X 1 = 4

ODD NUMBER OF MODULES IN ROW



X DENOTES PLACES TO INSTALL WEEB-PMC

C X R = 5 X 1 WEEB-PMC NEEDED = [C+1] X R = [5+1] X 1 = 6

Note:

When replacing a single faulty module, also remove the adjacent module which contacts the same WEEBs as the faulty module. This will ensure that there are never ungrounded modules in the array.

6

WEEBLUG ASSEMBLY



Important note: WEEB-6.7 that sits under the WEEBLug is for SINGLE USE ONLY! Ensure position is correct before tightening.

Wiley Electronics LLC. 2006-2010© - All Rights Reserved





WEEB BONDING JUMPER ASSEMBLY

(9) WEEB Bonding Jumper can be used for all rail splices including expansion joints.

