

NFRC Product Certification Authorization Report



Manufacturer: Grupo Eurowindows S.A. De C.V.
Street: Carretera Federal KM 200, Parcela No. 240
City/State/Zip: Bahia de Banderas, Nayarit 63735
Print Date: 04/10/2012

Product Series: 2000 Dual Action Window
Product Type: DATT
Air Leakage:

Simulation Lab: SATI
Sim. Report #: B4482.01-116-45
Sim. Report Date: 01/11/2012
Test Date: 01/05/2012

Initial Cert. Date: 04/09/2012
Re-Certification Date:
Revised Date: 01/11/2012
Expiration Date: 01/05/2016

CPD Number: GEW-A-4

IA: American Architectural Manufacturers Association

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00001-00001	E366 / arg / clr - (3.9mm/3.9mm) 24mm	VA/VA	2	0.022(2)	0.630	SS-D	Fill 1: ARG/AIR (90/10)	N		CL	0.28	0.19	0.44	62
	00002-00001	E270 / arg / clr - (3.9mm/3.9mm) 24mm	VA/VA	2	0.037(2)	0.630	SS-D	Fill 1: ARG/AIR (90/10)	N		CL	0.29	0.25	0.48	62
	00003-00001	E272 / arg / clr - (3.9mm/3.9mm) 24mm	VA/VA	2	0.042(2)	0.630	SS-D	Fill 1: ARG/AIR (90/10)	N		CL	0.29	0.29	0.49	61
	00004-00001	clr / arg / clr / arg / E272 - (3.9mm/3.9mm/3.9mm) 35mm	VA/VA	3	0.042(5)	0.453,0.453	SS-D	Fill 1: ARG/AIR (90/10), Fill 2: ARG/AIR (90/10)	N		CL	0.24	0.32	0.45	65
	00005-00001	clr / arg / clr / arg / E366 - (3.9mm/3.9mm/3.9mm) 35mm	VA/VA	3	0.022(5)	0.453,0.453	SS-D	Fill 1: ARG/AIR (90/10), Fill 2: ARG/AIR (90/10)	N		CL	0.23	0.27	0.40	65
	00006-00001	clr / arg / E366 / arg / E366 - (3.9mm/3.9mm/3.9mm) 35mm	VA/VA	3	0.022(3),0.022(5)	0.453,0.453	SS-D	Fill 1: ARG/AIR (90/10), Fill 2: ARG/AIR (90/10)	N		CL	0.20	0.21	0.32	66
	00007-00001	E366 / arg / lami - (3.9mm/3.9mm- 090SGP-3.9mm) 24mm	VA/VA	2	0.022(2)	0.453	SS-D	Fill 1: ARG/AIR (90/10)	N		CL	0.27	0.19	0.43	62
	00007-00002	E366 / arg / lami - (3.9mm/3.9mm- 090PVB-3.9mm) 24mm	VA/VA	2	0.022(2)	0.453	SS-D	Fill 1: ARG/AIR (90/10)	N		CL	0.27	0.19	0.43	62

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TATI	01/05/2012	1200mm x 1499mm	0.291	0.285	B4483.01-116-46-R0

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA
Signature: _____