


INSTALLATION SHEET FOR MODEL EP-037 EVAPORATOR PAD

The EP-037 replacement evaporator pad is designed for use with the Hamilton model 12HF whole house water saver humidifier. The evaporator pad should be replaced a minimum of once per heating season during unit operation, and should be inspected periodically as it may need replaced more often depending upon the hardness of the water in the home. The cartridge design keeps the water contained so that it travels within the path in the air flow.

Replacement Instructions

1. Remove front cover from the 12HF Humidifier.



2. Lift pad guard, and remove the evaporator pad.
3. Install new evaporator pad making sure that the large opened end is at the top, and the rounded edge faces forward.



4. Once seated properly, lock pad in position with the pad guard, replace front cover, and cycle to ensure the humidifier functions without leaking.