

1100 SERIES: 24 HR TIME SWITCHES SPECIFICATION WRITER'S GUIDE

Furnish and install where shown a TORK Time Switch with 24 hour dial. The Time Switch shall be powered by a self-starting synchronous motor. Time Switch contacts shall be capable of switching 40 amperes per pole continuously at 277 volts and shall be SPST (DPST, SPDT, as required). Removable ON-OFF trippers shall make possible automatic operation with a minimum ON period of 20 minutes and a minimum of 2 hours between one OFF period and the next. Enclosure shall be NEMA 1 surface type, finished in beige enamel, with combination 1/2", 3/4" knockouts on bottom, both sides and back. Provision shall be made for positive padlocking. Terminals shall be capable of receiving #8 AWG wire. Time Switch shall be TORK Model 11__ (11__ __, etc, to fit requirement).