

Certificate of Compliance

Certificate: 1160039 (LR 92886-37)

Project: 70180070

Master Contract: 153555

Date Issued: 20

2018-04-06

Issued to: Schneider Electric USA, Inc. Square D 3700 6th St SW Cedar Rapids, Iowa 52404 USA Attention: Manuel Salinas

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ronald Tateishi Ronald Tateishi

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Circuit breakers, Types QO and QOB, thermal magnetic trip, uncompensated, one-and two-pole, 10-70A, 240V ac max, 48V dc max and three-pole, 10-60A, 240V ac max, 48V dc max.

Notes:

- 1. The mechanism is trip-free of the handle, which assumes a mid-position between on and off upon automatic tripping.
- 2. These circuit breakers are suitable for use with copper and aluminum conductors.
- 3. These circuit breakers may be provided with shunt trip, auxiliary and bell alarm accessories.
- 4. The 15 and 20, 1-pole circuit breakers are suitable for switching fluorescent lighting loads and may be marked "SWD".

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 1160039 (LR 92886-37)

Master Contract: 153555

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

| Project | Date | Description |
|----------|------------|---|
| 70180070 | 2018-04-06 | Covers two revised constructions of the 3-pole, 35-60A circuit breakers. |
| 70107122 | 2017-04-18 | Addition of an alternate stationary and moving contact on the 35-50A circuit breakers. |
| 70077406 | 2016-05-25 | Update to Report 1160039 to cover revised construction of the QO230H. |
| 2516417 | 2012-04-25 | Increase in the VH ratings from 30A to 70A for the 1-pole circuit breakers. |
| 2502249 | 2012-02-27 | Revised construction of the QO(B), QO(B)-VH and QH(B), 3-pole, 15-30A, circuit breakers. |
| 2423526 | 2011-05-10 | Revised construction of the QO(B), QO(B)-VH and QH(B), 3-pole, 15-30A and the QO(B), 3-pole, 35-60A circuit breakers. |
| 2381494 | 2011-01-11 | Revised wire temperature rating on the #6 AWG conductors to 75C only. |
| 2333628 | 2010-08-12 | Addition of an arc stack on the QO(B), 3-pole, 10A circuit breakers. |
| 2212629 | 2009-08-26 | Revised construction of the QO(B)-H, 2-pole, 15-30A circuit breakers. |
| 1978847 | 2007-12-13 | Addition of an alternate arc chute/plate on the 240V, 35-60A, 10kA, 2- and 3-pole breakers. |
| 1818390 | 2006-10-13 | Revised toggle spring on the 60 and 70A, 1- and 2-pole circuit breakers. |
| 1680965 | 2005-06-06 | Addition of alternate case materials. |
| | | |

Product Certification History