

Project Number  
17.03183



**HUBBELL**  
Lighting

Date  
1/2/2017

LAB 6

### Test Sample Description

Catalog Number: P2143-2030K9

Description: LED Bathroom Wall-Mount w/ Two HAL AC LED Modules

IES LM-46-04

Test Method: IES LM-79-08 § 10

Preburn 1:00

Time To Stabilize: 0:45

Total Operating Time: 4:35

Input Voltage (Volts): 119.8

Input Current (Amps): 0.142

Input Wattage (Watts): 15.90

Ambient Temp (°C): 24.2



### Hubbell Lighting, Inc.

701 Millennium Boulevard  
Greenville, SC 29607  
www.hubbellighting.com

Checked: M. ELLMANN  
Approved: P. McCARTHY



This report shall not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government.