


## INSTALLATION INSTRUCTIONS

<u>∕</u>!\WARN I NG

ON GAS SUPPLY LINE IN ACCORDANCE
WITH NFPA54/ANSI Z223. 1FUEL GAS CODE.



PRIOR TO INSERTING PLUG TEST THE CONNECTION FOR LEAKS ONLY WITH LEAK TEST SOLUTION.
RINSE WITH CLEAN WATER AFTER LEAK TEST TO REMOVE ANY CORROSIVE RESIDUE.
DO NOT USE OPEN FLAME TO TEST FOR LEAKS.

## OPERATION INSTRUCTIONS

To connect-push back sleeve of socket (FIG. 1).

Insert Plug (FIG. 2). release sleeve.

Push Plug until sleeve snaps forward locking Plug in Socket (FIG. 3).

(THIS TURNS ON GAS AUTOMATICALLY)

To disconnect: Push sleeve back and pull out plug

(THIS AUTOMATICALLY SHUTS OFF GAS)

