

Project Number
16.02189



Date
8/27/2016

LAB 1

Test Sample Description

Catalog Number: P2144-2030K9

Description: Ace Led Bath & Vanity w/ Etched Glass Refractor & 3- HAL AC LED Module

Test Method: IES LM-79-08 § 10

Preburn Time: 0:10

Time To Stabilize: 1:05

Total Operating Time: 1:34

Input Voltage (Volts): 120.2

Input Current (Amps): 0.213

Input Wattage (Watts): 23.9

Ambient Temp (°C): 25.1



Hubbell Lighting, Inc.

701 Millennium Boulevard
Greenville, SC 29607
www.hubbellighting.com

Checked: D. ROBBINS
Approved: D. BLACK



This report shall not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government.